



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2200572

Circuit-breakers with overcurrent protection (CBO)

Type designation:

RI5*

Certificate holder:

ISKRA, d.o.o
Stegne 21, SI-1000 Ljubljana,
Slovenia

The product complies with the standard(s):

EN 60898-1:2019

Date of expiry:

27 October , 2025

EU Directive information:

According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body:

Intertek Semko AB, Product Certification

Place:

Kista - Stockholm

Signed:

Date:

11 May, 2022

Lief Mattsson

APPENDIX:

Reference No. SE-S-2200572

Technical Data:

Type designation RI5*
Rated voltage (V) 240/415V~(230/400V~) for 1P 240V~(230V~) for 1P+N 415V~(400V~)
for 2P, 3P, 3P+N, 4P
Rated current (A) 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 45, 50, 63A(1P) 6, 10, 16, 20, 25, 32, 40, 50,
63A (1P+N, 2P, 3P, 3P+N, 4P)
Frequency (Hz) 50/60Hz
IP-Class IP20
Poles No. 1P, 1P+N, 2P, 3P, 3P+N, 4P
Trademark



Test Report 220400514SHA-001
Product information Ics= Icn= 6000A; B- & C- Type
Explanation of type designation RI5*: The symbol * denotes the number of poles: 1 for 1P, 1N for 1P+N, 2 for 2P, 3 for 3P, 3N for 3P+N, 4 for 4P.

Manufacturing Sites: 30,113

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU. This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

However, this certificate is valid only after the following provisos have been attended to:
The product shall, from the safety point of view, be completely identical with the previously certified type AUB1 as shown in S certificate SE-S-2002514.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 11 May, 2022

Lief Mattsson